

333 Pfingsten Road
Northbrook, Illinois 60062-2096
United States Country Code (1)
(847) 272-8800
FAX No. (847) 272-8129
<http://www.ul.com>



March 11, 2002

Mr. Darrel P. Higgs
Owens Corning World Headquarters
One Owens Corning Parkway, 2A
Toledo, OH 43659

Our Reference: R2453

Dear Mr. Higgs:

This is to confirm that Classic® or Classic® AR, Supreme® or Supreme® AR, Prominence® or Prominence® AR, Oakridge® PRO 30™ or Oakridge® PRO 30™ AR (Oakridge® 25 or Oakridge® 25 AR), Oakridge® PRO 40™ or Oakridge® PRO 40™ AR (Oakridge® 30 or Oakridge® 30 AR), Oakridge® PRO 50™ or Oakridge® PRO 50™ AR (Oakridge® 40 or Oakridge® 40 AR), and WeatherGuard™ 40 High Wind 110 or WeatherGuard™ 40 AR High Wind 110 are Listed in accordance with ANSI/UL790, Class A (ASTM E 108, Class A), ASTM D3462, UL 997/ASTM D3161 (modified to 110 mph) secured with 4 nails.

All the products have been tested and meet the criteria for these standards and are covered by UL's Follow-Up Service Program for File R2453. If any further questions arise on the above, please contact the writer.

Very truly yours,

Very truly yours,

A handwritten signature in black ink, appearing to read 'Martin K. Rowan', is written over a horizontal line.

Martin K. Rowan (Ext. 42349)
Senior Project Engineer
Fire Protection Division

A not-for-profit organization
dedicated to public safety and
committed to quality service