



**Underwriters
Laboratories Inc.®**

Northbrook Division
333 Pingster Road
Northbrook IL 60062 2096 USA
www.ul.com
tel: 1-847-772-8800

March 16, 2005

Tamko Roofing Products
Ms. Kerri Eden
P.O. Box 1404
220 W. 4th Street
Joplin, MO 64802-1404

Our Reference: R2919

This is to confirm that "Elite Glass-Seal AR", "Heritage 30 AR", "Heritage 50 AR" manufactured at Tuscaloosa, AL and "Elite Glass-Seal AR", "Heritage 30 AR", "Heritage XL AR", "Heritage 50 AR" manufactured at Frederick, MD are UL Listed asphalt glass mat shingles and have been evaluated in accordance with ANSI/UL 790, Class A (ASTM E108), ASTM D3462, ASTM D3161 or UL 997 modified to 110 mph when secured with four nails.

Let me know if you have any further questions.

Very truly yours,

Alpesh Patel (Ext. 42522)
Engineer Project
Fire Protection Division

Reviewed by,

Randall K. Laymon (Ext. 42687)
Engineer Sr Staff
Fire Protection Division